



pcba

Pollution Control Board, Assam
Bamunimaidam, Guwahati-21

SHORT NOTICE INVITING QUOTATION

No. WB/G-1268/16-17/156

Dated Guwahati the, 18th June, 2018

Sealed quotation are invited from registered and experience contractors / firm for supplying 11/0.4 KV, 315 KVA Transformer to Pollution Control Board, Assam. Quotations will be received upto **2.30 PM on 09.07.2018** and will be opened on the same day at 3.30 PM in presence of quotationer or their authorize representatives. In case the day of submission of the quotations happens to be a holiday on account of Govt. Notification, the tenders shall be received and opened on the next working day at 3.30 PM for which no separate communication will be made. Other terms & conditions are as per **Appendix – A**.

Name of Work : Supply and installation of 11/0.4 KV, 315 KVA Transformer to the Head Office, Pollution Control Board, Assam at Bamunimaidam, Guwahati-21 (Assam).

Last Date of issue of paper for quotation : 06.07.2018

Last Date & Time for submission : Upto 2.30 PM on 09.07.2018

Date & Time for opening : 3.30 PM on 09.07.2018

Time of Completion : 1 (one) month

Member Secretary

Memo No. WB/G-1268/16-17/156-A,

Dated, Guwahati the, 18th June, 2018

Copy to:

1. P.A. to the Chairman, PCBA for kind appraisal of the Hon'ble Chairman.
2. The ACEE/SEE/REE; RO / RLO; Guwahati / Bongaigaon / Silchar / Sivasagar / Dibrugarh / Golaghat / Tezpur / Nagaon, PCBA for information & requested to put up the Notice on the Notice Board of the office for wide circulation.
3. The Asstt. Manager (F&A), Head Office, PCBA for information & necessary action.
4. Website (www.pcbassam.org) / Notice Board of the Board's Head Office, PCBA.

Member Secretary

SPECIFICATIONS AND OTHER TERMS & CONDITIONS

A. SPECIFICATION:

1. KVA Ratings - 315 KVA (CEA Specification)
2. No Load Voltage Ratio - 11/0.433 KV
3. Number of Phases - Three Phase
4. Type of Cooling - ONAN
5. Frequencies - 50 C/S
6. Vector Group - DYn11
7. Connections - Delta/Star
8. Temperature Rise in OIL - 35 °C
9. Temperature Rise in Windings - 40 °C
10. Material of Winding - Copper Wound
11. High Voltage terminal arrangement - Bushing
12. Low Voltage terminal arrangement - Bushing
13. Fittings & Accessories to be Supplied with the Transformer:
 - I. Name & Diagram Plate with Rating.
 - II. Earthling terminals
 - III. Lifting Lugs
 - IV. Top Filter valve
 - V. Arching Horns
 - VI. Oil Filling Hole with Cover
 - VII. Air Release Plug
 - VIII. Drain valve
 - IX. First Filling of Oil as per ISS 335 (latest)
 - X. Oil Conservator with Oil Level gauge
 - XI. Thermometer Pocket
 - XII. Silicagel Breather
 - XIII. Pressed Steel Radiators
 - XIV. Cable Box on LV Side
 - XV. Under base Channel
 - XVI. Explosion vent

B. TERMS & CONDITIONS:

1. Rates should be quoted in figure & words in letter pads or plain papers with a submission letter addressed to the Member Secretary, PCBA. If any variations arises between the rates in figures and words the rate whichever is lower shall be considered.
2. Leaflets if available or colour photographs of the items should be submitted with the quotation. Failure to which the quotation will be rejected without further communication.
3. All pages of the quotation and documents shall be signed and dated at the lower right hand corner by the quotationer or by a person holding power of attorney authorizing him to sign on behalf of the quotationer before submission of the Quotation.
4. The rates, taxes (GST) and loading & unloading and transportation, installation charge, etc. of all items to supply at Head Office, Pollution Control Board, Assam, Bamunimaidam, Guwahati-21 should be shown in details with break up.
5. Any abnormal rate quoted in the quotation will summarily be rejected for which no communication will be made.
6. Registration certificate of the firm/manufacturer/dealers/vendors, pan card No., sales tax clearance (Teen No.) and income tax clearance certificate, GST registration certificate should be submitted with the quotation (attested Xerox copies).
7. Any quotation submitted without the documents mentioned above will be considered as incomplete and the incomplete quotation will be rejected for which no communication will be made.
8. A Guarantee letter should be enclosed with the quotation with detailed proposal of Guarantee and Free Service period.
9. Payment will be made by cheque within 15 (fifteen) days after completion of installation and submission of Bill whichever is latter.
10. Copy of the detail Quotation Inviting Notice should attached with the Quotation after signing at the lower right hand corner on each page by the Quotationer or his authorized person as a token of acceptance of the terms & conditions of the Quotations inviting notice.
11. All disputes will be subjected to the jurisdiction of Guwahati Court only.



Member Secretary
Pollution Control Board, Assam